

SZYMON KAŻMIERCZAK\*

SELECTED ISSUES OF PRESTRESSED CONCRETE  
CONTAINMENT TANKS FOR THE STORAGE  
OF LIQUEFIED GASES DESIGN IN ACCORDANCE  
WITH EN 14620

WYBRANE ZAGADNIENIA PROJEKTOWANIA  
ZBIORNIKÓW Z BETONU SPRĘŻONEGO  
DO MAGAZYNOWANIA SKROPLONYCH GAZÓW  
W UJĘCIU EN 14620

Abstract

In 2014, a new tank for the storage of liquefied ammonia (capacity 22 000 m<sup>3</sup>) was built for the chemical industry company 'Grupa Azoty S.A.'. The LNG terminal in Świnoujście, where two large capacity containers (160 000 m<sup>3</sup> each) were built, is almost finished (2015). In both cases, prestressed concrete was used to build a secondary (outer) containment tank. This paper is devoted to general concepts and design considerations for secondary cylindrical, concrete containers for the storage of refrigerated, liquefied gases with temperatures between 0°C and -165°C, according to EN 14620.

*Keywords: prestressed concrete, cylindrical storage tanks, liquefied gases, low temperature*

Streszczenie

W 2014 roku przedsiębiorstwo przemysłu chemicznego Grupa Azoty S.A. oddało do użytku nowy zbiornik do magazynowania skroplonego amoniaku o pojemności 22 tys. m<sup>3</sup>. Prace związane z budową terminala LNG w Świnoujściu, gdzie powstały dwa zbiorniki o dużej pojemności (160 tys. m<sup>3</sup> każdy), są niemal ukończone (2015). W obu wymienionych przypadkach konstrukcję zbiornika zewnętrznego wykonano z betonu sprężonego. Artykuł przedstawia ogólne koncepcje i zasady projektowania zewnętrznych walcowych zbiorników z betonu do magazynowania skroplonych gazów o temperaturach pomiędzy 0°C i -165°C, według normy EN 14620.

*Słowa kluczowe: beton sprężony, zbiorniki cylindryczne, skroplone gazy, niska temperatura*

DOI: 10.4467/2353737XCT.15.166.4341

\* Ph.D. Eng., Szymon Kaźmierczak, Institute of Building Materials and Structures, Faculty of Civil Engineering, Cracow University of Technology.

## 1. Introduction

The current version of standard EN 14620[1] specifies the recommendations for materials, design rules, construction details and installation principles for above ground containment tanks for the storage of liquefied, refrigerated gases.

Liquefied gas has to be stored at a temperature equal to its atmospheric boiling point (Table 1). The correct temperature level in combination with a small overpressure ( $\leq 500$  mbar) is necessary in order to achieve equilibrium between liquid and vapour phases inside the storage tank.

Table 1

### Physical properties of pure gases [1.1]

Name	Chemical formula	Mol. mass [g/mol]	Boiling point [°C]	Latent heat of vapour at boiling point [kJ/kg]	Liquid density at boiling point [kg/m <sup>3</sup> ]	Gas density at boiling point [kg/m <sup>3</sup> ·10 <sup>-8</sup> ]	Vol. of gas liberated by 1 m <sup>3</sup> of liquid (exp. to 15 [°C] at 1 [bar]) [m <sup>3</sup> ]
N-Butan	C <sub>4</sub> H <sub>10</sub>	58 123	-0.5	385	601	270	239
Izo-Butan	C <sub>4</sub> H <sub>10</sub>	58 123	-11.7	366	593	282	236
Amoniak	NH <sub>3</sub>	17 030	-33.3	1367	682	905	910
Butadien	C <sub>4</sub> H <sub>6</sub>	54 091	-4.5	417	650	255	279
Propan	C <sub>3</sub> H <sub>8</sub>	44 096	-42.0	425	582	242	311
Propylen	C <sub>3</sub> H <sub>6</sub>	42 080	-47.7	437	613	236	388
Etan	C <sub>2</sub> H <sub>6</sub>	30 069	-88.6	487	546	205	432
Etylen	C <sub>2</sub> H <sub>4</sub>	28 054	-103.7	482	567	208	482
Metan	CH <sub>4</sub>	16 043	-161.5	509	422	181	630


Note 1: Commercial butane is a mixture in N-Butane and isobutane with a small content of propane and pentane.

Note 2: Commercial propane is propane with a small content of ethane and butane.

## 2. Concepts of the tank construction

Cylindrical tanks for the storage of liquefied gases are designed on the grounds of four general concepts. Taking into account risk assessment, a certain type of tank construction should be selected:

- **Single containment tank** (Fig. 1a) – in this solution, there is only one (*primary*) self-supporting, steel cylindrical tank to store the liquid product. This primary containment tank may be surrounded by an outer steel tank designed as a vapour barrier or as protection for thermal insulation. Due to the risk of leakage, a single containment tank should be surrounded by a bund wall.



Key:

- |   |  |
|---|--|
| 1. Primary container (steel)                  | 9. Steel roof                                      |
| 2. Primary container (membrane)               | 10. Concrete roof                                  |
| 3. Secondary container (steel)                | 11. Loose fill insulation                          |
| 4. Secondary container (prestressed concrete) | 12. External insulation                            |
| 5. Foundation                                 | 13. Outer shell (not capable of containing liquid) |
| 6. Foundation heating system                  | 14. Bund wall                                      |
| 7. Flexible insulating seal                   | 15. Cover (rain shield)                            |
| 8. Suspended roof (insulated)                 |  |

Fig. 1. Examples of containment tanks: a) single, b) double, c) full, d) membrane [1.1]

- **Double containment tank** (Fig. 1b) – consists of an inner, primary container (liquid and product vapour barrier) and an outer, secondary containment tank (only liquid barrier in case of leakage from a primary tank). This outer (steel or prestressed concrete) tank should ensure the containment of the whole volume of liquid stored inside the primary tank. The annular space, between both containers, should not be greater than 6.0 m and needs to be protected by a steel shield against rain, snow, dirt etc.
- **Full containment tank** (Fig. 1c) – the primary (inner) and the secondary (outer) container form one integrated tank. Contrary to the ‘double containment tank’ the secondary containment (steel or prestressed concrete) tank should be equipped with a dome roof. Both containers are designed to contain liquid. In cases where the primary tank is open at the top, the product vapours are contained in the outer tank. The annular space between the primary and the secondary containers should not exceed 2.0 m.

- **Membrane tank** (Fig. 1d) – consists of a thin steel membrane and load-bearing thermal insulation working together with a concrete container equipped with a dome roof. In the case of membrane leakage, the secondary concrete tank should be able to hold liquid and the product vapours.

### 3. Liquid tightness

The prestressed concrete secondary tank should ensure liquid and/or vapour tightness. Liquid leakage through concrete can be prevented in two ways [1.3]:

- Liners (steel plates) or reinforced/unreinforced polymer coatings may be used as a liquid (or vapour) barrier applied on the internal surface of the concrete. If concrete cracking occurs, the liner/coating should prove to be capable of ‘bridging’ a gap equal to 120% of the calculated crack width.
- A minimum compression zone in the concrete cross-section:  $x_{\min} = 100$  mm.

The selection of the type of wall to base connection is an important aspect of liquid tightness. It could be designed as: a sliding joint, pinned joint and fixed joint (Fig. 2). The last connection type is preferred for liquid tightness, but in the case of LNG tanks, it has to be thermally protected due to the risk of cracking in the case of leakage from the primary tank.




Fig. 2. Typical connections between the prestressed tank wall and the base: a) sliding joint, b) pinned joint, c) fixed joint [1.3]

#### 4. Load cases

Typical load cases for the prestressed concrete outer tank in all phases of its operational life according to BS 7777-3 [5] are presented in Table 2. In the case of the design values of actions, the effects of actions, material properties, geometric data and design resistance, the reference should be made to EN 1992-1-1 [3]. Recommended values of partial factors for accidental actions are shown in table 3. There is lack of reference to EN 1991-4 [6] in the range of load combinations or the values of partial load factors.

Table 2

**Design situations for prestressed concrete secondary containment [5]**

Loading conditions	Normal loads										Emergency loads							
	Con- struc- tion		Test		Cool down		Opera- tion		Mainte- nance		Leak- age		Blast		Earth- quake		Fire	
	W	B	W	B	W	B	W	B	W	B	W	B	W	B	W	B	W	B
Dead weight of concrete	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+
Dead weight of steel tank		+		+		+		+		+		+		+		+		+
Live load	(+)	+					+	+		+								
Pressure				+		+		+		+	+	+	+	+	+	+	+	+
Wind load	+		+		+		+		+		+		(+)		(+)		+	
Prestressing	+	(+)	+	(+)	+	(+)	+	(+)	+	(+)	+	(+)	+	(+)	+	(+)	+	(+)
Shrinkage	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+
Creep	+	+	+	+	+	+	+	+	+	+								
Temperature					(+)	+	(+)	+			+	+		+		+	+	+
Leakage											+	+						
Blast													+	(+)				
Earthquake															+	+		
Fire																	+	

+ applicable, (+) not always applicable, W – tank wall, B – tank base

**Partial load factors for accidental actions [1.3]**

Load combinations	Load factors					
	Dead		Imposed		Abnormal	Wind
	Adverse	Beneficial	Adverse	Beneficial	–	–
Normal actions + one accidental action	1.05	1.0	1.05	0	1.0	0.3
Accidental actions: earthquake (SSE), blast overpressure, external impact, fire or leakage from inner tank*						

\* In the case of leakage from the primary container it shall be assumed that the secondary container is filled gradually and can contain the whole liquid from the inner tank.

Table 4

**Hydrostatic tests [1.5]**

Contents	Single containment	Double containment	Full containment	Membrane tank
Ammonia, butane, propane, propylene	Tank (type I–II steels) FH	Inner tank (type I–II steels): FH	Inner tank (type I–II steels): FH	–
		Outer tank (type I–II steels): FH	Outer tank (type I–II steels): FH	–
		Outer tank (prestressed concrete): no test	Outer tank (prestressed concrete): no test	Outer tank (prestressed concrete): PH
Ethane, ethylene, LNG	Tank (type IV steel) PH	Inner tank (type IV steel): PH	Inner tank (type IV steel): PH	–
		Outer tank (type IV steel): PH	Outer tank (type IV steel): PH	–
		Outer tank (prestressed concrete): no test	Outer tank (prestressed concrete): no test	Outer tank (prestressed concrete): PH
FH <sup>1)</sup> – Full height hydrostatic test; PH <sup>2)</sup> – Partial height hydrostatic test				

- 1) Full height (FH) hydrostatic test – the inner tank should be filled to the maximum design liquid level.
- 2) Partial height (PH) hydrostatic test – the inner tank should be filled to a level equalling 1.25 times the height of the maximum design liquid level multiplied by the density of the specified product to be stored.

In both cases, the same quantity of water should be used for the testing of the outer tank.

## 5. Hydrostatic tests

Hydrostatic tests should be carried out to prove that the tank is well designed and constructed to contain the product with no leakage and that its foundation is able to support the tank contents. In the case of the prestressed concrete outer tank, this type of testing is not required (Table 4) – one exception is the membrane tank, which should be hydrostatically tested before the insulation membrane is installed.

## 6. Material properties under cryogenic conditions

Concrete is well suited for the storage of cryogenic liquids because the majority of its properties improve substantially as temperature is lowered into the cryogenic range (Table 5). In the case of the prestressed concrete tanks, concrete of at least the class C40/50 should be used.

Table 5

Ranges of 'normal' and 'low' temperatures for concrete and steel

Standard	Concrete		Prestressed steel		Normal steel	
	Normal	Low	Normal	Low	Normal	Low
MC2010 [7,8]	$0^{\circ}\text{C} \leq T \leq +80^{\circ}\text{C}$	$T < 0^{\circ}\text{C}$	$-40^{\circ}\text{C} \leq T \leq +40^{\circ}\text{C}$	$T < -40^{\circ}\text{C}$	$-40^{\circ}\text{C} \leq T \leq +40^{\circ}\text{C}$	$T < -40^{\circ}\text{C}$
PN-EN 1992-1-1 [3]	$0^{\circ}\text{C} \leq T \leq +80^{\circ}\text{C}$	$T < 0^{\circ}\text{C}$	$-40^{\circ}\text{C} \leq T \leq +100^{\circ}\text{C}$	$T < -40^{\circ}\text{C}$	$-40^{\circ}\text{C} \leq T \leq +100^{\circ}\text{C}$	$T < -40^{\circ}\text{C}$
PN-EN 1992-3 [4]	$-25^{\circ}\text{C} \leq T \leq +20^{\circ}\text{C}$	$T < -25^{\circ}\text{C}$	$-40^{\circ}\text{C} \leq T \leq +100^{\circ}\text{C}$	$T < -40^{\circ}\text{C}$	$-40^{\circ}\text{C} \leq T \leq +100^{\circ}\text{C}$	$T < -40^{\circ}\text{C}$
PN-EN 14620-3 [1]	$T \geq -20^{\circ}\text{C}$	$T < -20^{\circ}\text{C}$	$\geq -50^{\circ}\text{C}$	$T < -50^{\circ}\text{C}$	$T \geq -20^{\circ}\text{C}$	$T < -20^{\circ}\text{C}$

### 6.1. Concrete compressive strength

The compressive strength of the concrete increases with cryogenic temperatures [7]. The influence of the low temperature and moisture content on the concrete compressive strength gain  $\Delta f_{cm}$  (Fig. 3) can be estimated from formula (1):

$$\text{MC2010} \quad \Delta f_{cm}(T, mc) = 12mc \left[ 1 - \left( \frac{T+170}{170} \right)^2 \right] \text{ if } 0^{\circ}\text{C} \geq T \geq -170^{\circ}\text{C} \quad (1)$$

where:

- $T$  – the temperature [ $^{\circ}\text{C}$ ];
- $mc$  – the percentage of moisture content by mass.




Fig. 3. Increase of compressive strength  $\Delta f_{cm}$  as a function of temperature and moisture content (Van der Veen, 1987) [9]

In practice, the following values of  $m$  may be assumed:

- 2% (general indoor);
- 4% (general outdoor);
- 6% (exposed to rain).

### 6.2. Compressive stress – strain relation for concrete

The influence of temperature on the stress-strain relationship (Fig. 4) can be expressed by equation (2):

$$MC2010 \quad \sigma_c(t) = f_c(T, mc) \cdot \left[ 1 - \left( 1 - \frac{\varepsilon_c(T)}{\varepsilon_{fc}(T)} \right)^n \right] \quad (2)$$

where:

- $\sigma_c(t)$  and  $\varepsilon_c(T)$  – are stress and strain at a given point of the stress – strain curve,
- $\varepsilon_{fc}(T)$  – is the strain at ultimate strain,
- $n$  – exponent  $n$ :

$$n = \begin{cases} 2 & \text{for } T = 0^\circ\text{C} \\ 1 + \frac{T + 170}{170} & \text{for } -17^\circ\text{C} < T < 0^\circ\text{C} \\ 1 & \text{for } T = -170^\circ\text{C} \end{cases} \quad (3)$$






Fig. 4. Relative stress – strain relationship for concrete [9]

The ultimate strain  $\epsilon_{fc}(T)$  may be estimated as:

$$\epsilon_{fc}(T) = \epsilon_{fc}(T = 20^\circ\text{C}) + \kappa \cdot \Delta\epsilon_{fc}^{\max}(T = -60^\circ\text{C}) \quad (4)$$

where:

- concrete strain at ‘normal’ temperature:  $\epsilon_{fc}(T = 20^\circ\text{C}) = 0.2\%$
- coefficient  $\kappa$ :

$$\kappa = \begin{cases} 1 - \left( \frac{T + 60}{60} \right) & \text{if } T > -60^\circ\text{C} \\ \frac{T + 170}{110} & \text{if } -170^\circ\text{C} < T \leq -60^\circ\text{C} \end{cases} \quad (5)$$

- maximum increase in strain experienced at  $-60^\circ\text{C}$ :

$$\Delta\epsilon_{fc}^{\max} = \begin{cases} 0.1\% & \text{für Portland cement-based concretes} \\ 0.15\% & \text{for blast furnace cement-based concretes} \end{cases}$$

### 6.3. Concrete splitting tensile strength

The splitting tensile strength  $f_{c,spli}$  can be calculated according to the expression:

$$\text{MC 2010} \quad f_{c,spli}(T, mc) = C \cdot f_c(T, mc)^{0.67} \quad (6)$$

The value of coefficient  $C$  varies between 0.3 (air-dry concrete) and 0.56 (water saturated concrete).

A similar equation for tensile strength  $f_{ctx}$  is recommended in PN-EN 1992-3 [4]:

$$EC2-3 \quad f_{ctx} = \alpha \cdot f_{ckT}^{2/3} \quad (7)$$

The values of coefficient  $\alpha$  are shown in Table 6.

Table 6

**The coefficient  $\alpha$  [4]**

Tensile strength	Water saturated concrete	Dry concrete
$f_{ctm}$	0.47	0.30
$f_{ctk,0.05}$	0.27	0.21
$f_{ctk,0.95}$	0.95	0.39

#### 6.4. Concrete modulus of elasticity

The modulus of elasticity  $E_c$  increases with decreasing temperature. According to EC2-3 [4], the influence of the moisture content on the modulus of elasticity gain  $\Delta E_c$  can be estimated as:

$$EC2-3 \quad \Delta E_c (T = -25^\circ\text{C}) \approx \begin{cases} +2 \text{ GPa} & \text{for dry concrete} \\ +8 \text{ GPa} & \text{for water saturated concrete} \end{cases}$$

For concrete exposed to temperature  $T = -165^\circ\text{C}$ , the modulus of elasticity increases significantly [8]:

$$MC 2010 \quad E_c (T = -165^\circ\text{C}) \approx \begin{cases} 1.15 \times E_c (T = 20^\circ\text{C}) & \text{for dry concrete} \\ 1.5 \times E_c (T = 20^\circ\text{C}) & \text{for sealed concrete} \\ 1.8 \times E_c (T = 20^\circ\text{C}) & \text{for water saturated concrete} \end{cases}$$

#### 6.5. Coefficient of thermal expansion

The coefficient of thermal expansion  $\alpha_T$  decreases with reductions in temperature. The value of coefficient  $\alpha_T$  strongly depends on the content of free moisture in concrete (Fig. 5). In the case of water saturated concrete, expansion behaviour (negative value of coefficient  $\alpha_T$ ) should be expected. For dry concrete, the coefficient of thermal expansion decreases by approximately 10% [8].




Fig. 5. Effect of a) type of aggregates, and b) moisture content, on the value of the coefficient of thermal expansion  $\alpha_r$  [9]

## 6.6. Behaviour of normal and prestressed steel under cryogenic conditions

Generally, in the case of normal steel, the values of tensile strength, yield strength and the modulus of elasticity increase if the temperature decreases. The total elongation [in %] at maximum force increases initially but below  $-150^{\circ}\text{C}$ , it decreases rapidly [10]. Tests on prestressing steel wires and strands showed that 0.1% proof stress and ultimate strength was higher than at room temperature and an elongation at maximum load was over 2% at temperature  $T = -196^{\circ}\text{C}$  [11]. In both cases, normal and prestressing steel stress-strain diagrams are suitable for behaviour assessment at cryogenic temperature [8]. If the designed temperature is lower than  $-50^{\circ}\text{C}$ , then the prestressing system (strands and anchorages) should be tested in assumed cryogenic conditions. A tensile test on notched and un-notched reinforcing steel bars should be conducted if the designed temperature is lower than  $-20^{\circ}\text{C}$  [1.3].

## 7. Tank foundation design

Two types of foundation may be designed to prevent the ground freezing:

- shallow foundation (concrete slab on ground);
- pile foundation (elevated concrete foundation, Fig. 6).

The temperature of the concrete slab foundation should not drop below  $0^{\circ}\text{C}$  at any point. In the case of shallow foundation, a concrete slab heating system must be designed. An effective way to avoid the ground freezing is the existence of an air gap under the foundation. In this solution, the base slab is heated by natural air convection and an additional heating system for the tank foundation is not necessary.




Fig. 6. Geometry of the cryogenic tank with pile foundation (according to EN 1473[12])

## 8. Summary

This paper presented some general concepts of prestressed concrete containment tank constructions, load cases or combinations and material properties under cryogenic conditions according to EN 14620 and fib Model Code 2010. It concentrated on the main differences in the design aspects of concrete tanks in the case of ‘normal’ and ‘low’ temperature.

## References

- [1] EN 14620:2010 Design and manufacture of site built, vertical, cylindrical, flat-bottomed steel tanks for the storage of refrigerated, liquefied gases with operating temperatures between 0°C and –165°C.
  - [1.1] Part 1: General;
  - [1.2] Part 2: Metallic components;
  - [1.3] Part 3: Concrete components;
  - [1.4] Part 4: Insulation components;
  - [1.5] Part 5: Testing, dryling, purging and cool-down;
- [3] EN 1992-1-1:2008 Eurocode 2: Design of concrete structures – Part 1-1: General rules and rules for buildings .
- [4] EN 1992-3:2008 Eurocode 2: Design of concrete structures – Part 3: Liquid retaining and containment structures.
- [5] BS 777-3:1993 Flat-bottomed, vertical, cylindrical storage tanks for low temperature service.
  - Part 3: Recommendations for the design and construction of prestressed and reinforced concrete tanks and tank foundations, and for the design and installation of tank insulation, tank liners and tank coatings.
- [6] EN 1991-4:2008 Eurocode 1 – Actions on structures – Part 4: Silos and tanks.
- [7] fib Model Code 2010, Bulletin 55, First complete draft – Volume 1, March 2010.
- [8] fib Model Code 2010, Bulletin 56, First complete draft – Volume 2, April 2010.
- [9] Van der Veen J.C., *Properties of concrete at very low temperatures. A survey of the literature*, Report No. 25–87–2. Delft University of Technology, 1987.
- [10] FIP Special Report SR 88/2: Information on the behaviour at very low temperatures of ribbed steels, June 1988.
- [11] FIP State of the Art Report: Cryogenic behaviour of materials for prestressing concrete, 1982.
- [12] EN 1473:2007 Installation and equipment for liquefied natural gas –Design of onshore installations.